

Clearance of the exterior wall material

The clearance of the exterior wall material to the roof material was less than 2" and has or can allow moisture to damage the wall material. If the wall material is too close to the roof material, the inspector may not be able to tell if flashing is present or properly installed. Creating clearance of 2' between the exterior wall material and roof with the proper flashing installed helps prevent damage and leaks.